



Values

None: Default (3 Meter)
A0±0 Meter (Inlet only, no power cord)
A18±0.5 Meter
A18±0.6 Meter (2ft)
A7±1 Meter
A1=1.5 Meter
A1=1.6 Meter
A2±2 Meter
A2±2 Meter
A3±2.5 Meter
A3±3 Meter
A3±3 Meter
A3±3 Meter
A3±5.5 Meter
A1±4.6 Meter
A3±6.5 Meter
A1±6.5 Meter
A1±6.5 Meter
A1±6.5 Meter
A1±6.6 Meter
A1±6.6 Meter
A1±6.7 Meter
A1±

A brand of 🖾 legrand

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, INC. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN Mar. 27, 2017 Drawing Maker: EVA Lin PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM Design Engineer: Siang_H Mar. 27, 2017 RARITAN, INC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO Approver: Tom_H Mar. 27, 2017 CHANGE WITHOUT NOTICE..

PROJECTION THIRD ANGLE

DO NOT SCALE DRAWING SHEET 1 OF 1

iPDU Zero U Single Phase, 16A/200-240V Inlet Type: IEC60320 C20 Plug Type: NEMA L6-20P Outlet Type: C13 (24), C19 (6)

DWG NO.

PX3-1354V

52 [2,1"]

43 [1,7"]

2A

NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS (INCHES).
4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE.
BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.
5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.
6. LENGTH OF THE CORD IS 3000MM-/-70MM
7. DIMENSION TOLERAKCE: LENGTH -/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM
8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION