



- NOTES:
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLIMETERS (INCHES).
 4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLLESS MOUNT FOR 3RD PARTY ENCLOSURE. BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.
 5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.
 6. LENGTH OF THE CORD IS 3000MM +/- 70MM
 7. DIMENSION TOLERANCE: LENGTH +/- 3MM, WIDTH +/- 1MM, DEPTH +/- 0.5MM
 8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION

| Option | Description | Values |
|--------|-------------------------|--|
| A0-A18 | Length of the line cord | None: Default (3 Meter) A0=0 Meter (Inlet only, no power cord) A18=0.5 Meter A13=0.6 Meter (2ft) A7=1 Meter A1=1.5 Meter A16=1.8 Meter A2=2 Meter A8=2.5 Meter A14=2.6 Meter A3=3 Meter A9=3.5 Meter A4=4 Meter A5=4.5 Meter A6=5 Meter A15=5.5 Meter A12=6 Meter A11=6 Meter A10=8 Meter A17=10 Meter Note: For inline meters, double Ax will be used, first Ax is for the input cords, and the 2nd Ax is for the output cords. |

| | | | |
|--|---------|---|--|
| <p>Raritan A brand of legrand</p> | | PROJECTION THIRD ANGLE DO NOT SCALE DRAWING SHEET 1 OF 1 | TITLE: iPDU Zero U Single Phase, 16A/100-120V Inlet Type: IEC60320 C20 Plug Type: IEC60320 C20 Outlet Type: 5-20R (20) |
| | | | |
| Drawing Maker: | EVA LIN | Jan. 18, 2017 | DWG NO. PX3-5407CV & PX3-4407CV |
| Design Engineer: | Siang_H | Jan. 18, 2017 | |
| Approver: | Tom_H | Jan. 18, 2017 | |
| | | | REV. 2A |