



- NOTES:

  1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.

  2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.

  3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS [INCHES].

  4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE.


  BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.

  5. BRACKET KITS TO MOUNT TO SPECIFIC SAP PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.

  6. LENGTH OF THE CORD IS 3000MM-/-70MM

  7. DIMENSION DICERANCE: EINCHT H-/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM

  8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION





Drawing Maker:	Eva Lin	June 09. 2017
Design Engineer:	Sam_L	June 09. 2017
Approver:	Tom_H	June 09. 2017



DO NOT SCALE DRAWING SHEET 1 OF 1

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, Inc. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, Inc. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: iPDU Zero U

Three Phase, 40A/380-415V Plug Type: 40A Terminal 3PY Outlet Type: C13 (24) C19 (12)

MPX3-4744YU M5 & MPX3-5744YU M5

PX3-4744YU & PX3-5744YU PX3-4744YU-M5 & PX3-5744YU-M5 **2A** 

REV.