




**VIEW A VIEW B** 






VIEW C(Rotated 180 degrees)


VIEW D







- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
- 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS [INCHES].
- 4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE. BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.
- 5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.
- 6. RARITAN STANDARD LENGTH OF THE CORD IS 3000MM+/-70MM
- 7. DIMENSION TOLERANCE: LENGTH +/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM





Drawing Maker:	Eva Lin	Jun. 08, 2023
Design Engineer:	Eva Lin	Jun. 08, 2023
Approver:	Tom Hsueh	Jun. 08, 2023



TO CHANGE WITHOUT NOTICE.

DO NOT SCALE DRAWING SHEET 1 OF 1

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, Inc. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, Inc. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT

iPDU One U 100-120V, 15A Inlet Type: IEC60320 C20 Plug Type: NEMA 5-15P PSE Outlet Type: NEMA 5-20R (8), 15A

DWG NO. MPX3-5145JR & MPX3-4145JR

PX3-5145JR & PX3-4145JR

REV. **2B**