

- NOTES:

 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.

 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.

 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS INIGHES!.

 4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE.


 BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.

 5. BRACKET KITS TO MOUNT TO SPECIFIC SAP PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.

 6. LENGTH OF THE CORD IS 3000MM-/-70MM

 7. DIMENSION DILERANCE: EIGHTH 1-/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM

 8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION



A brand of 🗓 legrand

| Drawing Maker: | Eva Lin | Dec. 04, 2017 |
|------------------|---------|---------------|
| Design Engineer: | Sam_L | Dec. 04, 2017 |
| Approver: | Tom H | Dec. 04, 2017 |



DO NOT SCALE DRAWING SHEET 1 OF 1

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, Inc. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, Inc. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: iPDU Zero U

Single Phase, 16A/200-240V InputType: IEC60320 C20 Plug Type: IEC60309 16A OutputType: C13 (24)

MPX3-5486V M5 & MPX3-4486V M5

PX3-5486V & PX3-4486V PX3-5486V-M5 & PX3-4486V-M5

REV. 2C