



- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 1. INSTALLATION SHALL COMPLY WITH A LL APPLICABLE NATIONAL, STATE AND LOCAL CODES.

 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.

 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS (INCHES).

 4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE.


 BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.

 5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.

 6. LENGTH OF THE CORD IS 3000MM-/-70MM

 7. DIMENSION TOLERANCE: LENGTH -/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM

 8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION



A brand of Li legrand

Aug. 29, 2017 Eva Lin Drawing Maker: Aug. 29, 2017 Design Engineer: Siang_H Tom_H Aug. 29, 2017 Approver:



DO NOT SCALE DRAWING SHEET 1 OF 1

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, Inc. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, Inc. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE

TITLE: iPDU Zero U

Three Phase, 16A/380-415V Plug Type: IEC60309 16A 3PY Outlet Type: Locking C13 (24), Locking C19 (6)

MPX3-5648-E2 M5 & MPX3-4648-E2 M5

PX3-5648-E2 & PX3-4648-E2 PX3-5648-E2M5 & PX3-4648-E2M5 2A

REV.